



ISSN: 2350-0328

**International Journal of Advanced Research in Science,  
Engineering and Technology**

**Vol. 6, Issue 9, September 2019**

# **Detection of Errors in the Vibration Diagnostics of Pump Units**

**Bekjanov Faxriddin, Khudayev Ibrohim, Turdibekov Ilhomjon**

Associate professor, Tashkent Institute of Irrigation and Agricultural Mechanization Engineers, the Republic of  
Uzbekistan

Candidate of technical sciences, dotsent, Tashkent Institute of Irrigation and Agricultural Mechanization Engineers, the  
Republic of Uzbekistan

Associate professor, Tashkent Institute of Irrigation and Agricultural Mechanization Engineers, the Republic of  
Uzbekistan

**ABSTRACT:** This article provides a mathematical model and analytical calculations to determine the amount of vibration that occurs in pump units.

**KEYWORDS:** vibration diagnostics; accelerometer; equipment; signal; vibration accelerations; vibration speed; mathematical model; pump; diagnostics; reliability; tests; device; probability of failure-free operation; spectrogram; vibrations.

## **I. INTRODUCTION**

Currently, in our country, using water lifting machines, more than 50% of arable land is irrigated. The system of water supply to the water users depends on the technical condition of the pump units used, various technical and technological measures are applied to ensure their reliable operation. Theoretical research and analysis, taking into account the specificity of pump units, carrying out research work on the development and use of modern diagnostic equipment, is one of the most pressing issues of our day [1].

## **II. METHODS**

Analysis of the use of hydro mechanical equipment in the lifting machine system has shown that one of the main causes of their failure is vibration, it is important to identify and analyze it. Determination of vibrations in pump units, which are part of hydro-mechanical equipment, measurements have been made to study their current state, it can be achieved in the future. As a result of the introduction of pumping system diagnostics, along with the reasons for the disruptions in the operation. They will be identified without technical damage, and a database on how long they can be used without interruption will be generated [2].

The pump unit is a complex system, in the process of changing their status over time, such indicators should be selected, be able to assess the actual state of the system as a result of determining these parameters. This task is performed during the pump unit operation and during the first phase of use, its indicators are maintained or changed insignificantly. This is achieved during this period as parts of the pump unit provide consistent performance. Investigating changes between interconnected elements in the system and the correct formulation of the diagnostic matter is required to determine the extent to which they can play a key role [3,4].

As a result of the analysis of the pump unit operation, it was found that the interconnection between its parts can be divided into a three-tier system. The first stage is a pump unit that contains energy and mechanical components, it consists of a pump unit and an electric motor. In turn, the pump unit and the electric motor are the second step, its elements consist of details and parts and interconnections between them. The links between these parts are of the type of mechanical bonding and are part of the kinematic pair. Since their movement has one or more degrees of freedom, it is regarded as a system consisting of separate parts, which may be included in the movement of common mechanical systems.

This means that each element that forms them has a different dimension than the stationary coordinate system. These indicators are qualitative characteristics of mechanical bonding, the structure of the structure (distance between the axis and axis, bending, etc.). The third stage of the system consists of separate details that are part of the second phase, characterized by their molecular composition. Changes in their content lead to changes in the design of materials. Such cases include cracks, cracks, corrosion and causing damage due to erosion effects[4,9].

Usually, accelerometer vibrations are recorded at certain points on the machine, and vibrations are recorded. This signal is converted into vibrations or vibrations by integrating on a device or computer called a vibrator. These three types of signals are considered to be cyclic polygenic processes in vibration diagnostics [5].

When performing vibration diagnostics with accelerometer mounted at specific points of the machine, the signal is usually recorded in the form of vibrations. This signal is transformed into vibrations or vibrations by integrating on a device or computer called a vibration collector. All these three types of gestures are considered to be cyclic polygenic processes in vibration diagnostics [6,7,8].

Mathematical modeling is usually aimed at solving equations given the operation of pump units in different operating modes. A special program has been developed to accurately assess the impact of changes in operating modes on pump units. Using the software, it is possible to determine the optimal operation of pump units.

**Results.** The values obtained as a result of sudden measurements during measurement can be uncertain. Therefore, it is necessary to determine the threshold values for each parameter measurement. These values are determined taking into account the errors made during the diagnosis [10,11].

The probability of making a mistake is determined by the following expression:

$$\Omega = \Omega_1 + \Omega_2;$$

where:  $\Omega_1$  – the probability of displaying a malfunction when the system is in operation;

$\Omega_2$  – the condition of perceiving the system as defective in case of any defects.  $M+1(j=0,1,2...M)$  position,  $N$  ( $i=1,2...N$ ) high for each case of diagnostic parameters  $Y_{ji}$  and the bottom  $P_{ji}$  the state of their vectors using boundary values  $> [P_j$  and  $Y_j]$  when measured at intervals.

$$P_j > Y_j \tag{1}$$

That is, the defined value  $P_{ji}$  and  $Y_{ji}$  between two boundaries  $N$  – if located between dimensional parallelepiped  $j$  the case. The lower bound was not used in this case.

If the obtained data is not linked to the above data,  $\Omega_1$  of  $j$  the condition that occurs for the chi state is determined by the following expression.

$$\Omega_{1j} = \Omega(\gamma_o) \prod_{i=1}^N \int_{P_{ji}}^{Y_{ji}} f(\tilde{\chi}_i / \gamma_o) d \tilde{\chi}_i \tag{2}$$

$J$  the probability of chi is determined by the following expression.

$$\Omega_{2j} = \Omega(\gamma_j) \prod_{i=1}^N \int_{P_{oi}}^{Y_{oi}} f(\tilde{\chi}_i / D_j) d \tilde{\chi}_i \tag{3}$$

where:  $\gamma_o$  - density of the required standard position,

$\gamma_j$  - the likelihood of an unusual situation.

$M$  the probability of a standard deviation being false is:

$$\Omega_1 = \Omega(\gamma_o) \sum_{j=1}^M \prod_{i=1}^N \int_{P_{ji}}^{Y_{ji}} f(\tilde{\chi}_i / D_o) d \tilde{\chi}_i \tag{4}$$

$M$  probability of detecting an event

$$\Omega_2 = \sum_{j=1}^M \Omega(\gamma_j) \prod_{i=1}^N \int_{P_{oi}}^{Y_{oi}} f(\tilde{\chi}_i / D_j) d \tilde{\chi}_i \tag{5}$$

where:  $\Omega(\gamma_j) - j$  the probability of a ir oor state.

In general, these parameters are not interrelated(3) - (5) orthogonalis changes are additionally accepted to detect errors in expression use. This type of substitution includes K with the covariance matrix type in its vectors.

$$Y' = K - Y;$$

(3) - (5) the new orthogonalis in expression is based entirely on the acquisition of Y, which is a spatial characteristic.

(1) The characteristic parameters are determined taking into account the regularity of the system and the signs of the defects. The resulting information is used for diagnostics. These parameters include harmonic parameters that exceed the value.

When diagnosing the condition of the pump blades, the number of hormonal foams is determined by multiplying the number of holes on the surface by the number of rotations of the work blade. To determine its value, the extrinsic values in the range studied are subtracted and numbered. When defects occur more than three times during detection or irregularly, their occurrence values are calculated using the following expression:

$$N_i = \frac{1}{n} \sum_{i=Z_{f_0-\frac{n}{2}}}^{Z_{f_0+\frac{n}{2}}} A(f_j) \quad (6)$$

where:  $n$  – the number of points in the interval;

$A(f_i) - f_i$  the amplitude of the spectra at the frequency.

One of the most common parameters during vibration measurement is vibration. Because vibration measurement and processing are determined by vibrations, you have to extract vibrational values from the spectrum.

To do this, we use the following expression to determine vibrations in the range of 10-1000 Hz values:

$$V = \frac{1}{2\pi} \sum_{i=10}^{1000} \frac{A(f_j)}{f_j} \quad (7)$$

Another parameter calculated using spectral amplitude is the depth of the modulation. It is calculated using the following expression:

$$\gamma(f) = \frac{A(f)}{\xi} \cdot 100\%;$$

where:  $A(f) - f$  frequency signals;

$\xi$ - the amount of signal that occurs.

Signal amount is a constant component of the detected signal. Its value is determined by the zero channel of the spectrum. Sohis expression will look as follows:

$$\gamma(f) = \frac{A(f)}{A(0)} \cdot 100\%;$$

Diagnostic parameters to determine the state of the aggregate are determined by this method [11].

### III. CONCLUSION

On the basis of the obtained data, the mathematical model, which represents the threshold values of parameters caused by irrigation pump units, allows calculating and predicting the probability of defects in pump units. The noise and vibration induced by hydrodynamic and mechanical oscillations are subject to similarity patterns. They can be calculated by calculating the rotation speed and size of the pumping wheel. This combination of characters allows you to determine the probability and amount of the defect.

### REFERENCES

1. Glovatsky O.Ya., Ergashev R.R, Bekchanov F.A. 2017 *Analysis of diagnostics of pumping units of Jizzakh head pumping station*. (Tashkent: Irrigation and melioration magazine №3 (9)). 32-34 p



ISSN: 2350-0328

# International Journal of Advanced Research in Science, Engineering and Technology

Vol. 6, Issue 9 , September 2019

2. Glovatsky O.Ya., Ergashev R.R, Bekchanov F.A. 2018 y *Results of diagnostics of pump units*. (Tashkent: Irrigation and melioration magazine №1 (11)) 36-39 p.
3. Majitov T.M., Ergashev R.R., Bekchanov F.A. / *Determination of the amount of vibration in the pump unit*. // «Environmental issues of rational use of water and land resources in irrigated agriculture» Republican scientific-practical conference. 2017 y, 24-25 November.
4. Bekchanov F.A. 2018 *New methods for diagnosing pumps hydrotechnical systems*. (Delhi: International journal for innovative research in multidisciplinary fields. Vol -4, Issue-10), 367-373 page.
5. Glovatsky O.Ya., Ergashev R.R, Bekchanov F.A, Rustamov Sh.R. 2012 *Estimation of the technical condition and availability of pumping units*. (Almaty: International Agroengineering, Scientific and Technical Journal.) 64-67 p.
6. Bekchanov F.A. 2012 *Vibration measuring equipment in pumps*. (Tashkent: Increase efficiency, reliability and safety of hydraulic structures. Republican Scientific and Practical Conference. TIIM) 30-32 p.
7. Bekchanov F.A. 2018 *Diagnostic device for pumps units*. (Andijan: International scientific-practical conference on "Problems of increasing the efficiency of production and energy efficiency of modern production.") 1071-1074 p.p.
8. Bekchanov F.A. 2018 *Vibro diagnostic system software* (Tashkent: International scientific-practical conference "Problems of increase of energy efficiency in agrarian sector.) 212-219 p.p.
9. Bekchanov F.A. 2018 *Providing safe operation of pump units by diagnostic method* (Tashkent: International scientific-practical conference "Problems of increase of energy efficiency in agrarian sector) 286-291 p.p.
10. Myntsov A.A. *Application of the envelope method for the diagnosis of mechanical components of equipment*. Materials-3. International Scientific and Practical Conference. "Resource Energy Saving".Dimitrov- "Promservis", 2001 y.- 250 s.
11. Vissarionov V. I. *Mathematical modeling of transients in pumping units*. // Problems and directions of development of hydraulic engineering // M.:Minximmash. 1978 y. 246 p.